



FIRE SAFETY BY DESIGNATED AGENCY CERTIFICATE

FIRE SERVICE LICENSE

**(Under Section 13 of the Tamil Nadu Fire Service Act 1985 and with
Tamil Nadu Fire Service Rules 1990 Appendix III)**

L.DIS.No. TN-3520240210121/B/2023

Date: 22-02-2024

LICENSE is here by granted under section 13 of the Tamil Nadu Fire Service Act 1985, for To Run Engineering College in the name of M/s. T.J.S. Engineering College within the jurisdiction of Peruvoyal at No.175, T.J.S. Nagar, Near Kavaraipettai, Gummidipoondi Taluk, Thiruvallur District. With total building area of 147644 Sq.fts with Subject to the condition mentioned below noted there on and such other conditions as may be prescribed. The above premises inspected by Station Officer, Gummidipoondi on 16-02-2024


CONDITIONS

As per Tamil Nadu Fire Service Act 1985 Section 13 of Chapter II and appendix V of this Act.

1. According to G.O. No.713 Home (Police-17) Department, Dated 17.08.2005 the Permanent employees & Safety employees who is responsible for the safety of working in the company should be trained.
2. This License is valid for **One Year** from the date of issue.
3. Regular License has to be obtained from the Competent Authority.
4. The Following Fire & Life safety Systems / Arrangements provided in the building should be kept in good working condition always.
 - a) Portable First Aid Fire Extinguishers – 42 Nos,
 - b) Fire Bucket with sand – 20 Nos
 - c) First Aid Box – 10 Nos
 - d) Sump 100000 ltrs and Borewell
5. As per NBC 2016 The Following Fire & Life Safety Systems / Arrangements should be provided within 6 months.
 - a) First Aid Hose Reel System Yard Hydrant with 450 LPM Pump should be Provided
 - b) Terrace Level Water Tank 20000 ltrs Should Be Provided
6. If there is any deviation from the Government Rule and Act the LICENSE issued will Stand Cancelled.
7. Mock Drill should be conducted once in 6 months along with nearby Fire & Rescue Service Stations.

(Office seal with date)




DISTRICT OFFICER,
FIRE & RESCUE SERVICES,
THIRUVALLUR DISTRICT,
THIRUVALLUR. 22/2

To:

M/s. T.J.S. Engineering College,
No.175, T.J.S. Nagar, Near Kavaraipettai,
Gummidipoondi Taluk,
Thiruvallur District.

Copy to:

Deputy Director, Fire & Rescue Service, North western Region, Vellore-1.



PRINCIPAL

T.J.S. ENGINEERING COLLEGE
Peruvoyal, Kavaraipettai,
Gummidipoondi Taluk,
Thiruvallur Dist - 601 206.